



**KELLER FIRE-RESCUE DEPARTMENT
FIRE PREVENTION DIVISION**

FIRE LANE STRIPING DETAIL
2018 IFC Section 503

1. Fire lanes shall be marked with a 6-inch wide continuous bright red stripe on both sides. **Where the curb is available, the striping shall be on both the horizontal and vertical faces of the curb.**
2. White 4 inch high lettering with a 1 inch stroke centered on red stripe shall read: **"NO PARKING FIRE LANE TOW AWAY"** or **"FIRE LANE NO PARKING TOW AWAY"**. This lettering shall be painted every 25 feet measured from the end of one lettering group to the beginning of the next group with 1 foot spacing between "NO PARKING," "FIRE LANE," and "TOW AWAY".

Color specification: Bright Red. Note: Red paint shall not be used for any parking lot markings other than fire lanes. The red paint shall meet the Texas Department of Highways and Public Transportation, (TXDOT), specification number TTP-115, chlorinated rubber paint or approved equal.



Where the curb is available, the striping shall be on both the horizontal and vertical faces of the curb

