



HORIZONTAL BLOCKING TABLE

DIMENSION "X" TO BE A MINIMUM OF (1) FOOT, BUT IS TO BE INCREASED WHERE NECESSARY TO PROVIDE BEARING AGAINST UNDISTURBED TRENCH WALL.

PIPE SIZE	"X" DIM.	PLUGS & TEES		90° BENDS		45° BENDS		22.50° BENDS		11.25° BENDS	
		"A"	MIN. AREA sf	"B"	MIN. AREA sf	"C"	MIN. AREA sf	"D"	MIN. AREA sf	"E"	MIN. AREA sf
6"	1'-6"	1'-0"	1.06	1'-2"	1.50	1'-0"	.83	1'-0"	.83	1'-0"	.83
8"	1'-6"	1'-3"	1.89	1'-6"	2.66	1'-3"	1.44	1'-0"	.83	1'-0"	.83
10"	1'-6"	1'-9"	2.95	2'-0"	4.17	1'-6"	2.26	1'-3"	1.15	1'-0"	.83
12"	1'-6"	2'-0"	4.25	2'-3"	6.00	1'-9"	3.25	1'-3"	1.65	1'-0"	.83
16"	2'-0"	2'-7"	7.54	3'-0"	10.65	2'-3"	5.76	1'-8"	2.94	1'-2"	1.48

NOTES:

1. BEARING AREAS SHOWN ARE BASED ON 150 PSI TEST PRESSURE AND 3000 PSF ALLOWABLE SOIL BEARING PRESSURE.
2. WRAP ALL BELOW GROUND IRON ASSEMBLIES IN POLYETHYLENE ACCORDING TO AWWA C105
3. ALL TEES, BENDS, PLUGS, ETC. SHALL BE MECHANICALLY RESTRAINED BY MEGALUG OR APPROVED EQUAL.

HORIZONTAL THRUST BLOCKING

SCALE: N.T.S.



WATER CONSTRUCTION DETAILS HORIZONTAL THRUST BLOCKING

REVISION DATE:
2/1/2024

SHEET: W-07