



NOTES:

1. SERVICES ALONG ROADWAYS WITHOUT CURB AND GUTTER SHALL BE LOCATED A MINIMUM OF 18" BELOW THE DITCH FLOWLINE.
2. SERVICE LINES CROSSING UNDER THE ROADWAY SHALL BE LOCATED A MINIMUM OF 30" BELOW GRADE AND BE ENCASED IN A 4" SCHEDULE 40 PVC PIPE.
3. METERS AND TAPS SHALL BE LOCATED ON SAME SIDE OF MAIN.

SERVICE LINE	2"
SERVICE SADDLE	FORD FC202-CC7 OR APPROVED EQUAL
CORPORATION STOP	FORD FB1000-7-G OR APPROVED EQUAL
ANGLE STOP	FORD BFA43-777WG OR APPROVED EQUAL
METER BOX W/ LID	DFW PLASTICS DFW65C-14-AF1F DEEP



**WATER CONSTRUCTION DETAILS**  
**2" WATER SERVICE ASSEMBLY**

REVISION DATE:  
2/1/2024

SHEET: W-14