

NOTES:

1. ALL GALVANIZED STEEL PIPE IS THREADED SCH. 40.
2. DRILL 4" DIAMETER HOLE THROUGH VAULT WALL FOR 2" PIPE. SEAL OPENING AROUND 2" PIPE INSIDE WITH A LATEX INSULATING FOAM AND OUTSIDE WITH AN ASPHALTIC JOINT SEALANT MATERIAL SUCH AS "RAM-NEK" OR APPROVED EQUAL.
3. WHEN NOT IN PAVING OR WALK, A 4. CONCRETE PAD, REINFORCED W/ #3 BARS AT 12" C-C EACH, WAY, SHALL EXTEND A MINIMUM OF 2' AROUND THE M.H. AND VENT PIPE, AND SHALL BE A MINIMUM OF 4" THICK.

