



SERVICE LINE	2"
SERVICE SADDLE	FORD FC202-CC7 OR APPROVED EQUAL
CORPORATION STOP	FORD FB1000-7-G OR APPROVED EQUAL
ANGLE STOP	FORD BFA43-777WG OR APPROVED EQUAL
METER BOX (BODY)	OLDCASTLE NO. B65 BODY
METER BOX (LID)	DFW PLASTICS 65C-1AF

NOTES:

- SERVICES ALONG ROADWAYS WITHOUT CURB AND GUTTER SHALL BE LOCATED A MINIMUM OF 18" BELOW THE DITCH FLOWLINE.
- SERVICE LINES CROSSING UNDER THE ROADWAY SHALL BE LOCATED A MINIMUM OF 30" BELOW GRADE AND BE ENCASED IN A 4" SCHEDULE 40 PVC PIPE.



WATER CONSTRUCTION DETAILS
2" MANUAL FLUSH VALVE ASSEMBLY

REVISION DATE:
2/1/2024

SHEET: W-22