



NOTES:

1. USE OF HYDRANT REQUIRES FIRE HYDRANT METER RENTAL APPLICATION. CONTACT KELLER UTILITY BILLING CUSTOMER SERVICE FOR APPLICATION.
2. METER AND REDUCER BACKFLOW PRESSURE ZONE (RPZ) BACKFLOW DEVICE SHALL BE FULLY SUPPORTED WHEN CONNECTED TO FIRE HYDRANT.
3. PRIOR TO ANY USE OF FIRE HYDRANT WATER, THE RPZ MUST BE TESTED BY A CITY-REGISTERED BACKFLOW PREVENTION ASSEMBLY TESTER (BPAT), AND A CURRENT AND PASSING TEST AND MAINTENANCE REPORT (TMR) FOR THE RPZ MUST BE PROVIDED WITH THE FIRE HYDRANT METER APPLICATION. BACKFLOW DEVICE SHALL BE TESTED ANNUALLY AND COPY OF TEST SHALL BE PROVIDED TO THE CITY BEFORE CONTINUED USAGE WILL BE ALLOWED.
4. CONTRACTOR WILL BE HELD RESPONSIBLE FOR ANY DAMAGE TO FIRE HYDRANT DURING USE.
5. SANDBAGS SHALL NOT OBSTRUCT WEEP HOLE.



**STANDARD FIRE HYDRANT  
METER INSTALLATION**

REVISION DATE:  
2/1/2024

SHEET: W-24