



REINFORCEMENT FOR CONCRETE PLUG

PIPE SIZE	REINF. BAR	DISTANCE C-C	S
18"-39"	#3	12" E.W.	1/2T
42"-54"	#3	12" E.W.	1/3T
60"-72"	#4	12" E.W.	1/4T

NOTE: STEEL HANDLE FOR REINFORCED CONCRETE PIPE PLUG SHALL BE LOCATED 1/4 I.D. ABOVE CENTER POINT OF PLUG. TWO STEEL HANDLES WILL BE REQUIRED ON PLUGS OF 36" PIPES OR LARGER AND SHALL BE PLACED 1/4 I.D. APART AND 1/4 I.D. ABOVE CENTER OF PLUG.



STORM DRAIN CONSTRUCTION DETAILS
CONCRETE PLUG

REVISION DATE:
2/1/2024

SHEET: D-10