



NOTES:

1. MINIMUM CHIMNEY HEIGHT SHALL BE 18" AS MEASURED FROM INSIDE TAPER ON CONE TO TOP OF COVER.
2. NO GAPS WILL BE ALLOWED IN BITUMASTIC GASKET.
3. THERE SHALL BE A SMOOTH TRANSITION BETWEEN THE FRAME GRADE RING, OR THE GRADE RING AND THE CONE.
4. CONCRETE GRADE RINGS MAY BE PRECAST OR CAST-IN-PLACE. BRICK EXTENSION RINGS WILL NOT BE ALLOWED.
5. STANDARD EXTENSIONS SHALL BE 2", 3", 4", 6", AND 12". EXTENSIONS SHALL BE SIZED TO MINIMIZE THE NUMBER REQUIRED TO RAISE THE MANHOLE LID.



SEWER SYSTEM CONSTRUCTION DETAILS
MANHOLE ADJUSTMENT

REVISION DATE:
2/1/2024

SHEET: S-12