



NOTE:

1. LOCAL - #3 BARS ON 18" O.C.E.W.
COLLECTOR/ARTERIAL - #4 BARS ON 18" O.C.E.W.
2. STREET RUNOFF CAPACITY TO BE CALCULATED BASED ON PARABOLIC CROWN ONLY.
3. MACHINE FINISHED CONCRETE SHALL HAVE A MAXIMUM SLUMP OF 4 INCHES AND A MIN. 3600 PSI COMPRESSIVE STRENGTH AT 28 DAYS, WITH UP TO 20% TYPE C FLY ASH REPLACEMENT ALLOWED.
4. HAND FINISHED CONCRETE SHALL HAVE A MAXIMUM SLUMP OF 5 INCHES AND A MIN. 3600 PSI COMPRESSIVE STRENGTH AT 28 DAYS. NO FLY ASH ALLOWED IN HAND FINISHED CONCRETE.

TYPICAL UNDIVIDED CONCRETE SECTION

SCALE: N.T.S.

STREET CLASSIFICATION	PAVEMENT THICKNESS	CROWN HEIGHT	STABILIZED SUBGRADE THICKNESS
LOCAL	6"	6"	6"
COLLECTOR	7"	7"	8"
ARTERIAL	8"	8"	9"



PAVING CONSTRUCTION DETAILS
TYPICAL UNDIVIDED CONCRETE STREET SECTION

REVISION DATE:
2/1/2024

SHEET: P-01